



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2201259

Low-voltage switchgear and controlgear - Part 3: Switch-disconnector

Type designation:	UKP0-3, UKP0-4, UKP1-3, UKP1-4, UKP3-3, UKP3-4, UKP5-3, UKP5-4
Certificate holder:	Zhejiang Kripal Electric Co., Ltd. Zhongfang Zhineng Industrial Park, Yueqing, Zhejiang, China
The product complies with the standard(s):	EN IEC 60947-3:2021
Date of expiry:	10 October, 2027
EU Directive information:	According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 10 October, 2022

Leif Mattsson

APPENDIX:

Reference No. SE-S-2201259

Technical Data:

<i>Type designation</i>	UKP0-3, UKP0-4, UKP1-3, UKP1-4, UKP3-3, UKP3-4, UKP5-3, UKP5-4
<i>Rated voltage (V)</i>	440~
<i>Rated current (A)</i>	10, 16, 20A (UKP0-3, UKP0-4), 20, 25, 32A (UKP1-3, UKP1-4), 32, 50, 63A (UKP3-3, UKP3-4) 50, 63, 80, 100A (UKP5-3, UKP5-4)
<i>Poles No</i>	3P, 3P+N, 4P
<i>Frequency (Hz)</i>	50/60
<i>IP-Class</i>	65
<i>Trademark</i>	KRIPAL
<i>Test Report</i>	220801410SHA-001, 220801410SHA-002, 220801410SHA-003, 220801410SHA-004
<i>Product information</i>	Icw= 12Ie, 1s Icm= 20Ie Cat. AC-22A

Manufacturing Sites:

Zhejiang Kripal Electric Co., Ltd.
Zhongfang Zhineng Industrial Park,
Yueqing, Zhejiang, China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 10 October, 2022

Leif Mattsson